

# CLASSIFICATION OF PROPERTIES MLTB-2733-2018- chapter I



Notified body NB 2189

for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A2:2016  
Assessment of the performance of the product on the basis of testing/ calculations

Company: **PRZEDSIĘBIORSTWO  
PRODUKCYJNO-USŁUGOWO-HANDLOWE  
Dariusz Malec**  
ul. Królowej Jadwigi 13 E, 78-200 Białogard

Product: fixed glazing; main profiles: pine wood

System:

**SKANDINOVA 68**

Test results are included in the following test reports registered under the number of the request MLTB-2733-2018



Air permeability  
PN-EN 1026




Waterproofness  
PN-EN 1027



Wind load resistance  
PN-EN 12211

Test methods:

Classification standards		PN-EN 12207	PN-EN 12208	PN-EN 12210
Product type (B x H mm)	<div></div> <div>1700 x 2251</div>	4	E1200	C3
Notes: none.				

## Mobilne Laboratorium Techniki Budowlanej Sp. z o. o.

- 1) assessment of the performance of the product made by
- 2) tests made by

*Head of Laboratory Mścichowski Adam  
older technician Domański Adam  
assistant technician Grzyb Adam*

14-03-2018, Wałbrzych

Term of control test within the FPC (ZKP): 14-03-2019

Initial Type Testing (ITT) remain valid until, if there is not change in the construction of window and external pedestrian doorset, the raw material or supplier of the components, or the production proces, which would affect significantly one or more of the characteristics. Consistently with PN-EN 14351-1+A2:2016 point 7.5 Continuous surveillance, assessment and approval of FPC, the producer should carry out FCP assessment together with current and quality control inspections of a product at least once a year. The inspections conducted in accordance with the inspection plan should confirm that the manufactured products have the same properties as the products subject to ITT.



Mobilne Laboratorium Techniki  
Budowlanej Sp. z o.o.  
NIP PL 8862868350  
REGON 020573602  
KRS 0000461727

58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok. 2  
tel.: +48 74 840 14 63, fax: + 48 74 661 41 40  
http://www.badaniaokien.pl  
e-mail: biuro@badaniaokien.pl

Notyfikowana jednostka  
(notified body) NB 2189

# CLASSIFICATION OF PROPERTIES MLTB-2726-2018- chapter I



Notified body NB 2189

for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A2:2016  
Assessment of the performance of the product on the basis of testing/ calculations

Company: **PRZEDSIĘBIORSTWO  
PRODUKCYJNO-USŁUGOWO-HANDLOWE  
Dariusz Malec**  
ul. Królowej Jadwigi 13 E, 78-200 Białogard

Product: single leaf window; main profiles: pine wood

System:

**SKANDINOVA 68**

Test results are included in the following test reports registered under the number of the request MLTB-2726-2018




Test methods:

Air permeability  
PN-EN 1026

Waterproofness  
PN-EN 1027

Wind load resistance  
PN-EN 12211

Security equipment capacity  
PN-EN 14609

Classification standards	PN-EN 12207	PN-EN 12208	PN-EN 12210	Threshold value
Product type (B x H mm)  1500 x 1550	<b>4</b>	<b>9A</b>	<b>C4</b>	<b>350 N</b>

Notes: enveloped hardware IPA.

## Mobilne Laboratorium Techniki Budowlanej Sp. z o. o.

- 1) assessment of the performance of the product made by *Head of Laboratory Mścichowski Adam*
- 2) tests made by *older technician Domański Adam*  
*assistant technician Grzyb Adam*

13-03-2018, Wałbrzych

Term of control test within the FPC (ZKP): 13-03-2019

Initial Type Testing (ITT) remain valid until, if there is not change in the construction of window and external pedestrian doorset, the raw material or supplier of the components, or the production proces, which would affect significantly one or more of the characteristics. Consistently with PN-EN 14351-1+A2:2016 point 7.5 Continuous surveillance, assessment and approval of FPC, the producer should carry out FCP assessment together with current and quality control inspections of a product at least once a year. The inspections conducted in accordance with the inspection plan should confirm that the manufactured products have the same properties as the products subject to ITT.



Mobilne Laboratorium Techniki  
Budowlanej Sp. z o.o.  
NIP PL 8862868350  
REGON 020573602  
KRS 0000461727

58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok. 2  
tel.: +48 74 840 14 63, fax: + 48 74 661 41 40  
http://www.badaniaokien.pl  
e-mail: biuro@badaniaokien.pl

Notyfikowana jednostka  
(notified body) NB 2189

# CLASSIFICATION OF PROPERTIES MLTB-2728-2018- chapter I



Notified body NB 2189

for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A2:2016  
Assessment of the performance of the product on the basis of testing/ calculations

Company: **PRZEDSIĘBIORSTWO  
PRODUKCYJNO-USŁUGOWO-HANDLOWE  
Dariusz Malec**  
ul. Królowej Jadwigi 13 E, 78-200 Białogard

Product: double-row window with two leaves; main profiles: pine wood

System:

**SKANDINOVA 68**

Test results are included in the following test reports registered under the number of the request MLTB-2728-2018



Air permeability  
PN-EN 1026




Waterproofness  
PN-EN 1027



Wind load resistance  
PN-EN 12211

Test methods:

Classification standards		PN-EN 12207	PN-EN 12208	PN-EN 12210
Product type (B x H mm)		4	8A	C5
	900 x 2250			
Notes: enveloped hardware IPA.				

## Mobilne Laboratorium Techniki Budowlanej Sp. z o. o.

- 1) assessment of the performance of the product made by *Head of Laboratory Mścichowski Adam*
- 2) tests made by *older technician Domański Adam*  
*assistant technician Grzyb Adam*

13-03-2018, Wałbrzych

Term of control test within the FPC (ZKP): 19-03-2019

Initial Type Testing (ITT) remain valid until, if there is not change in the construction of window and external pedestrian doorset, the raw material or supplier of the components, or the production proces, which would affect significantly one or more of the characteristics. Consistently with PN-EN 14351-1+A2:2016 point 7.5 Continuous surveillance, assessment and approval of FPC, the producer should carry out FCP assessment together with current and quality control inspections of a product at least once a year. The inspections conducted in accordance with the inspection plan should confirm that the manufactured products have the same properties as the products subject to ITT.



Mobilne Laboratorium Techniki  
Budowlanej Sp. z o.o.  
NIP PL 8862868350  
REGON 020573602  
KRS 0000461727

58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok. 2  
tel.: +48 74 840 14 63, fax: + 48 74 661 41 40  
http://www.badaniaokien.pl  
e-mail: biuro@badaniaokien.pl

Notyfikowana jednostka  
(notified body) NB 2189

# CLASSIFICATION OF PROPERTIES MLTB-2734-2018- chapter I



Notified body NB 2189

for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A2:2016  
Assessment of the performance of the product on the basis of testing/ calculations

Company: **PRZEDSIĘBIORSTWO  
PRODUKCYJNO-USŁUGOWO-HANDLOWE  
Dariusz Malec**  
ul. Królowej Jadwigi 13 E, 78-200 Białogard

Product: double-row window with four leaves; main profiles: pine wood

System:

**SKANDINOVA 68**

Test results are included in the following test reports registered under the number of the request MLTB-2734-2018



Air permeability  
PN-EN 1026




Waterproofness  
PN-EN 1027



Wind load resistance  
PN-EN 12211

Test methods:

Classification standards		PN-EN 12207	PN-EN 12208	PN-EN 12210
Product type (B x H mm)		4	6A	C3
	1400 x 2250			
Notes: enveloped hardware IPA.				

## Mobilne Laboratorium Techniki Budowlanej Sp. z o. o.

- 1) assessment of the performance of the product made by *Head of Laboratory Mścichowski Adam*
- 2) tests made by *older technician Domański Adam*  
*assistant technician Grzyb Adam*

15-03-2018, Wałbrzych

Term of control test within the FPC (ZKP): 15-03-2019

Initial Type Testing (ITT) remain valid until, if there is not change in the construction of window and external pedestrian doorset, the raw material or supplier of the components, or the production proces, which would affect significantly one or more of the characteristics. Consistently with PN-EN 14351-1+A2:2016 point 7.5 Continuous surveillance, assessment and approval of FPC, the producer should carry out FCP assessment together with current and quality control inspections of a product at least once a year. The inspections conducted in accordance with the inspection plan should confirm that the manufactured products have the same properties as the products subject to ITT.



Mobilne Laboratorium Techniki  
Budowlanej Sp. z o.o.  
NIP PL 8862868350  
REGON 020573602  
KRS 0000461727

58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok. 2  
tel.: +48 74 840 14 63, fax: + 48 74 661 41 40  
http://www.badaniaokien.pl  
e-mail: biuro@badaniaokien.pl

Notyfikowana jednostka  
(notified body) NB 2189

# CLASSIFICATION OF PROPERTIES MLTB-2727-2018- chapter I



Notified body NB 2189

for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A2:2016  
Assessment of the performance of the product on the basis of testing/ calculations

Company: **PRZEDSIĘBIORSTWO  
PRODUKCYJNO-USŁUGOWO-HANDLOWE  
Dariusz Malec**  
ul. Królowej Jadwigi 13 E, 78-200 Białogard

Product: three-leaves window; main profiles: pine wood

System:

**SKANDINOVA 68**

Test results are included in the following test reports registered under the number of the request MLTB-2727-2018




Test methods:

Air permeability  
PN-EN 1026

Waterproofness  
PN-EN 1027

Wind load resistance  
PN-EN 12211

Classification standards		PN-EN 12207	PN-EN 12208	PN-EN 12210
Product type (B x H mm)		4	8A	C5
	2200 x 1550			
Notes: enveloped hardware IPA.				

## Mobilne Laboratorium Techniki Budowlanej Sp. z o. o.

- 1) assessment of the performance of the product made by
- 2) tests made by

*Head of Laboratory Mścichowski Adam  
older technician Domański Adam  
assistant technician Grzyb Adam*

13-03-2018, Wałbrzych

Term of control test within the FPC (ZKP): 13-03-2019

Initial Type Testing (ITT) remain valid until, if there is not change in the construction of window and external pedestrian doorset, the raw material or supplier of the components, or the production proces, which would affect significantly one or more of the characteristics. Consistently with PN-EN 14351-1+A2:2016 point 7.5 Continuous surveillance, assessment and approval of FPC, the producer should carry out FCP assessment together with current and quality control inspections of a product at least once a year. The inspections conducted in accordance with the inspection plan should confirm that the manufactured products have the same properties as the products subject to ITT.



Mobilne Laboratorium Techniki  
Budowlanej Sp. z o.o.  
NIP PL 8862868350  
REGON 020573602  
KRS 0000461727

58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok. 2  
tel.: +48 74 840 14 63, fax: + 48 74 661 41 40  
http://www.badaniaokien.pl  
e-mail: biuro@badaniaokien.pl

Notyfikowana jednostka  
(notified body) NB 2189

# CLASSIFICATION OF PROPERTIES MLTB-2731-2018- chapter I



Notified body NB 2189

for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A2:2016  
Assessment of the performance of the product on the basis of testing/ calculations

Company: **PRZEDSIĘBIORSTWO  
PRODUKCYJNO-USŁUGOWO-HANDLOWE  
Dariusz Malec**  
ul. Królowej Jadwigi 13 E, 78-200 Białogard

Product: single leaf casement door; main profiles: pine wood

System:

**SKANDINOVA 68**

Test results are included in the following test reports registered under the number of the request MLTB-2731-2018




Test methods:

Air permeability  
PN-EN 1026

Waterproofness  
PN-EN 1027

Wind load resistance  
PN-EN 12211

Security equipment capacity  
PN-EN 14609

Classification standards		PN-EN 12207	PN-EN 12208	PN-EN 12210	Threshold value
Product type (B x H mm)		<b>4</b>	<b>8A</b>	<b>C4</b>	<b>350 N</b>
	1000 x 2250				

Notes: enveloped hardware IPA.

## Mobilne Laboratorium Techniki Budowlanej Sp. z o. o.

- 1) assessment of the performance of the product made by *Head of Laboratory Mścichowski Adam*
- 2) tests made by *older technician Domański Adam*  
*assistant technician Grzyb Adam*

14-03-2018, Wałbrzych

Term of control test within the FPC (ZKP): 14-03-2019

Initial Type Testing (ITT) remain valid until, if there is not change in the construction of window and external pedestrian doorset, the raw material or supplier of the components, or the production proces, which would affect significantly one or more of the characteristics. Consistently with PN-EN 14351-1+A2:2016 point 7.5 Continuous surveillance, assessment and approval of FPC, the producer should carry out FCP assessment together with current and quality control inspections of a product at least once a year. The inspections conducted in accordance with the inspection plan should confirm that the manufactured products have the same properties as the products subject to ITT.



Mobilne Laboratorium Techniki  
Budowlanej Sp. z o.o.  
NIP PL 8862868350  
REGON 020573602  
KRS 0000461727

58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok. 2  
tel.: +48 74 840 14 63, fax: + 48 74 661 41 40  
http://www.badaniaokien.pl  
e-mail: biuro@badaniaokien.pl

Notyfikowana jednostka  
(notified body) NB 2189

# CLASSIFICATION OF PROPERTIES MLTB-2735-2018- chapter I



Notified body NB 2189

for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A2:2016  
Assessment of the performance of the product on the basis of testing/ calculations

Company: **PRZEDSIĘBIORSTWO  
PRODUKCYJNO-USŁUGOWO-HANDLOWE  
Dariusz Malec**  
ul. Królowej Jadwigi 13 E, 78-200 Białogard

Product: double leaf casement door; main profiles: pine wood

System:

**SKANDINOVA 68**

Test results are included in the following test reports registered under the number of the request MLTB-2735-2018



Air permeability  
PN-EN 1026




Waterproofness  
PN-EN 1027



Wind load resistance  
PN-EN 12211

Test methods:

Classification standards		PN-EN 12207	PN-EN 12208	PN-EN 12210
Product type (B x H mm)		2	method A Npd	C2
	1800 x 2250			
Notes: enveloped hardware IPA.				

## Mobilne Laboratorium Techniki Budowlanej Sp. z o. o.

- 1) assessment of the performance of the product made by
- 2) tests made by

*Head of Laboratory Mścichowski Adam  
older technician Domański Adam  
assistant technician Grzyb Adam*

15-03-2018, Wałbrzych

Term of control test within the FPC (ZKP): 15-03-2019

Initial Type Testing (ITT) remain valid until, if there is not change in the construction of window and external pedestrian doorset, the raw material or supplier of the components, or the production proces, which would affect significantly one or more of the characteristics. Consistently with PN-EN 14351-1+A2:2016 point 7.5 Continuous surveillance, assessment and approval of FPC, the producer should carry out FCP assessment together with current and quality control inspections of a product at least once a year. The inspections conducted in accordance with the inspection plan should confirm that the manufactured products have the same properties as the products subject to ITT.



Mobilne Laboratorium Techniki  
Budowlanej Sp. z o.o.  
NIP PL 8862868350  
REGON 020573602  
KRS 0000461727

58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok. 2  
tel.: +48 74 840 14 63, fax: + 48 74 661 41 40  
http://www.badaniaokien.pl  
e-mail: biuro@badaniaokien.pl

Notyfikowana jednostka  
(notified body) NB 2189

# CLASSIFICATION OF PROPERTIES MLTB-2729-2018- chapter I



Notified body NB 2189

for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A2:2016  
Assessment of the performance of the product on the basis of testing/ calculations

Company: **PRZEDSIĘBIORSTWO  
PRODUKCYJNO-USŁUGOWO-HANDLOWE  
Dariusz Malec**  
ul. Królowej Jadwigi 13 E, 78-200 Białogard

Product: Single leaf external door; main profiles: pine wood  
System: **SKANDINOVA 68**  
Test results are included in the following test reports registered under the number of the request MLTB-2729-2018



Air permeability  
PN-EN 1026




Waterproofness  
PN-EN 1027



Wind load resistance  
PN-EN 12211

Test methods:

Classification standards		PN-EN 12207	PN-EN 12208	PN-EN 12210
Product type (B x H mm)		4	7A	C3
	1000 x 2250			
Notes: hinges IPA, the lock and lock cylinder Assa Abloy.				

## Mobilne Laboratorium Techniki Budowlanej Sp. z o. o.

- 1) assessment of the performance of the product made by *Head of Laboratory Mścichowski Adam*  
2) tests made by *older technician Domański Adam*  
*assistant technician Grzyb Adam*

14-03-2018, Wałbrzych

Term of control test within the FPC (ZKP): 14-03-2019

Initial Type Testing (ITT) remain valid until, if there is not change in the construction of window and external pedestrian doorset, the raw material or supplier of the components, or the production proces, which would affect significantly one or more of the characteristics. Consistently with PN-EN 14351-1+A2:2016 point 7.5 Continuous surveillance, assessment and approval of FPC, the producer should carry out FCP assessment together with current and quality control inspections of a product at least once a year. The inspections conducted in accordance with the inspection plan should confirm that the manufactured products have the same properties as the products subject to ITT.



Mobilne Laboratorium Techniki  
Budowlanej Sp. z o.o.  
NIP PL 8862868350  
REGON 020573602  
KRS 0000461727

58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok. 2  
tel.: +48 74 840 14 63, fax: + 48 74 661 41 40  
http://www.badaniaokien.pl  
e-mail: biuro@badaniaokien.pl

Notyfikowana jednostka  
(notified body) NB 2189

# CLASSIFICATION OF PROPERTIES

## MLTB-2736-2018- chapter I



Notified body NB 2189

for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A2:2016  
Assessment of the performance of the product on the basis of testing/ calculations

Company: **PRZEDSIĘBIORSTWO PRODUKCYJNO-USŁUGOWO-HANDLOWE Dariusz Malec**  
ul. Królowej Jadwigi 13 E, 78-200 Białogard

Product: double leaf external door; main profiles: pine wood  
System: **SKANDINOVA 68**  
Test results are included in the following test reports registered under the number of the request MLTB-2736-2018




Test methods:

Air permeability  
PN-EN 1026

Waterproofness  
PN-EN 1027

Wind load resistance  
PN-EN 12211

Classification standards		PN-EN 12207	PN-EN 12208	PN-EN 12210
Product type (B x H mm)		3	2B method A Npd	C2
	1800 x 2250			
Notes: hinges IPA, the lock and lock cylinder: Assa Abloy.				

### Mobilne Laboratorium Techniki Budowlanej Sp. z o. o.

- 1) assessment of the performance of the product made by *Head of Laboratory Mścichowski Adam*  
2) tests made by *older technician Domański Adam*  
*assistant technician Grzyb Adam*

15-03-2018, Wałbrzych

Term of control test within the FPC (ZKP): 15-03-2019

Initial Type Testing (ITT) remain valid until, if there is not change in the construction of window and external pedestrian doorset, the raw material or supplier of the components, or the production proces, which would affect significantly one or more of the characteristics. Consistently with PN-EN 14351-1+A2:2016 point 7.5 Continuous surveillance, assessment and approval of FPC, the producer should carry out FCP assessment together with current and quality control inspections of a product at least once a year. The inspections conducted in accordance with the inspection plan should confirm that the manufactured products have the same properties as the products subject to ITT.



Mobilne Laboratorium Techniki  
Budowlanej Sp. z o.o.  
NIP PL 8862868350  
REGON 020573602  
KRS 0000461727

58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok. 2  
tel.: +48 74 840 14 63, fax: + 48 74 661 41 40  
http://www.badaniaokien.pl  
e-mail: biuro@badaniaokien.pl

Notyfikowana jednostka  
(notified body) NB 2189